



- GENERAL CONSTRUCTION NOTES:
1. ALL CAST CONCRETE BASES AND WALLS SHALL HAVE # 4 REBAR @ 12" C-C EW
  2. CONCRETE SHALL BE 3000 PSI MIN.
  3. USE C.S.S. BEDDING AS PER DETAILS 1 1/2 SK, COMPACTED 8" LIFTS (MAX.) TO 95% STANDARD.

No.	DATE	REVISION

SEAL:

DESIGN ENGINEER: *Carlos J. Barillas* DATE: 5/13/13

CITY OF SUGAR LAND, TEXAS  
ENGINEERING DEPARTMENT

CONSTRUCTION PLANS FOR:

STORM SEWER MANHOLE  
CONSTRUCTION DETAILS

JOB No.:  
DATE:  
DESIGNED BY:  
DRAWN BY:  
CHECKED BY:  
SCALE:

SL-03  
SHEET OF

- REFER TO:
1. GENERAL NOTES, C.S.S. & CONCRETE NOTES.
  2. STORM SEWER NOTES